



Horizontal Tank Calibration Chart

Tank Diameter: 120.0 Inches

Tank Length: 204.0 Inches

Total Tank Capacity: 9987.8 Gallons

10,000 Gallon Tank

Inches of Void	Gallons of Sealer Remaining	Inches of Void	Gallons of Sealer Remaining	Inches of Void	Gallons of Sealer Remaining	Inches of Void	Gallons of Sealer Remaining
1	12.87	31	2044.91	61	5099.87	91	8126.44
2	36.30	32	2138.16	62	5205.81	92	8216.63
3	66.52	33	2232.35	63	5311.69	93	8305.71
4	102.15	34	2327.42	64	5417.48	94	8393.63
5	142.40	35	2423.35	65	5523.16	95	8480.33
6	186.70	36	2520.08	66	5628.68	96	8565.76
7	234.66	37	2617.59	67	5734.03	97	8649.87
8	285.96	38	2715.83	68	5839.17	98	8732.59
9	340.32	39	2814.76	69	5944.08	99	8813.87
10	397.54	40	2914.36	70	6048.71	100	8893.63
11	457.42	41	3014.58	71	6153.05	101	8971.82
12	519.81	42	3115.39	72	6257.06	102	9048.35
13	584.55	43	3216.75	73	6360.71	103	9123.15
14	651.51	44	3318.64	74	6463.96	104	9196.14
15	720.59	45	3421.02	75	6566.79	105	9267.22
16	791.67	46	3523.85	76	6669.17	106	9336.30
17	864.65	47	3627.10	77	6771.06	107	9403.26
18	939.46	48	3730.75	78	6872.42	108	9468.00
19	1015.99	49	3834.76	79	6973.23	109	9530.39
20	1094.18	50	3939.09	80	7073.45	110	9590.27
21	1173.94	51	4043.73	81	7173.04	111	9647.49
22	1255.22	52	4148.63	82	7271.98	112	9701.85
23	1337.94	53	4253.78	83	7370.22	113	9753.15
24	1422.05	54	4359.13	84	7467.72	114	9801.11
25	1507.48	55	4464.65	85	7564.46	115	9845.41
26	1594.18	56	4570.33	86	7660.38	116	9885.66
27	1682.10	57	4676.12	87	7755.46	117	9921.29
28	1771.18	58	4782.00	88	7849.65	118	9951.51
29	1861.37	59	4887.94	89	7942.90	119	9974.94
30	1952.63	60	4993.90	90	8035.18	120	9987.24

NOTE: Measurement of the void is to be done from where the actual tank starts, **NOT** in the manway.
Filling tank up with sealer into the manway may result in leakage of sealer out of manway onto tank.

6.30.08